

Town of Pelzer
SC0410008
Annual Drinking Water Quality Report
For the Year 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is Greenville Water System. Greenville Water System draws its water from the Table Rock Reservoir on the South Saluda River.

A Source Water Assessment Plan has also been completed for our system. For more information on this report, please contact SCDHEC Bureau of Water at 803-898-3531. If you have any questions concerning this Consumer Confidence Report (CCR) or your water utility, please contact Cheryl Boudreau at Town of Pelzer. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM in Pelzer Gym at 112 Leiby St., Pelzer, SC 29669.

Town of Pelzer routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

The following chart show our test results.

Non-Detects (ND) – laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level (AL)- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) – The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water.

MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

If present, elevated lead levels can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Pelzer is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or

cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in your drinking water, testing methods, and steps to minimize exposure is available from the Safe Drinking Water Hotline, 1-800-426-4791, or at <http://www.epa.gov/safewater/lead>.

TEST RESULTS Greenville Water System (SC2310001)

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Nitrate (2021)	N	0.063 Range 0.021-0.063	ppm	10	10	Erosion of natural deposits; runoff from fertilizer
Fluoride (2021)	N	0.67 Range 0.62-0.67	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Unregulated Contaminants						
Sodium (2021)	N	6.8 Range 6.8-6.8	Ppm	N/A	N/A	Naturally Occurring

Town of Pelzer (SC0410008)

Lead and Copper	Violation Y/N	90th percentile	Unit Measurement	Action Level	Sites over action level	Likely Source of
-----------------	---------------	-----------------	------------------	--------------	-------------------------	------------------

Copper (2021)	N	0.157	ppm	1.3	0	Contaminati on Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (2021)	N	0	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

<https://www.townofpelzer.us/documents/Town of Pelzer CCR 2021 report>